

PSO Business Rebates

2021 HVAC Midstream Technical Requirements

Air Conditioners			
Size (tons)	Tier 1 Min. Requirements	Tier 2 Min. Requirements	Tier 3 Min. Requirements
< 5.4	15 SEER	16 SEER	18 SEER
≥ 5.4 & < 11.25	11.7 IEER	12.0 IEER	13 IEER
≥ 11.25 & < 20	11.4 IEER	12.2 IEER	12.5 IEER
≥ 20 & < 63.3	10.8 IEER	11 IEER	12.0 IEER
≥ 63.3	10 IEER	10.3 IEER	11 IEER

Air Source Heat Pumps			
Size (tons)	Tier 1 Min. Requirements	Tier 2 Min. Requirements	Tier 3 Min. Requirements
< 5.4	15 SEER & 8.5 HSPF	16 SEER & 9 HSPF	18 SEER & 9.5 HSPF
≥ 5.4 & < 11.25	11.7 IEER & 3.4 COP	12.2 IEER & 3.5 COP	13 IEER & 3.6 COP
≥ 11.25 & < 20	11.4 IEER & 3.3 COP	12.2 IEER & 3.4 COP	12.5 IEER & 3.5 COP
≥ 20 & < 63.3	10.8 IEER & 3.3 COP	11 IEER & 3.4 COP	12.0 IEER & 3.5 COP
≥ 63.3	10 IEER & 3.3 COP	10.3 IEER & 3.4 COP	11 IEER & 3.5 COP

Dual Enthalpy (DE) Economizer Controls	Only eligible on new HVAC units.
---	----------------------------------

Packaged Terminal Air Conditioners (PTAC)	
Size (tons)	Min. Requirements
< 0.75	11.8 EER
≥ 0.75 & < 1.0	11.0 EER
≥ 1.0	10.3 EER

For more information, visit PowerForwardWithPSO.com, or call 888.776.1366.

Packaged Heat Terminal Heat Pumps (PTHP)	
Size (tons)	Min. Requirements
< 0.75	12 EER & 3.3 COP
≥ 0.75 & < 1.0	11.4 EER & 3.3 COP
≥ 1.0	10.5 EER & 3.3 COP

Variable Refrigerant Flow Units	
VRF - Cooling Only	
Size (tons)	Min. Requirements
≤20 Ton	18 SEER/IEER
VRF - Heat Pump	
≤20 Ton	18 SEER/IEER & 3.3 COP

Water Source Heat Pumps	
Category & Size	Min. Requirements
Building Loop <11 Tons	13 EER & 3.3 COP
Geothermal <11 Tons	14 EER & 3.3 COP

For more information, visit PowerForwardWithPSO.com, or call 888.776.1366.